



## 9335-NKFR

3.5" dia. round fan support box for use with nonmetallic sheathed cable *Replacement for 9335-NFR*

**Carton Quantity:** 50

**Mounting Description:** Nail-on with fether ring nails

**Box Type:** Ceiling - Fan/Fixture

**Box Features:** Nails, Speed "K" nonmetallic clamps

**Installation Type:** New Work

**Width:** 3-1/2 in

**Depth:** 2-7/8 in

**Volume:** 20.5 cu in

**Fan Rating:** 35lbs

**Fixture Rating:** 50lbs

## Product Info

**Brand:** fiberglassBOX

**UPC:** 85339412021

**UNSPSC:** 39121316

**Carton Weight:** 26 lbs

**Carton Length:** 20 in

**Carton Width:** 12 in

**Carton Height:** 16 in

**Country of Origin:** United States of America

**Color:** Off white

**Material:** Fiberglass reinforced polyester

**Additional Materials:** Carbon steel fasteners, Polyvinyl chloride clamps

**Box Diameter:** 3.5

## Features:

Machine tapped fixture holes, rigid hard box construction, no distortion with high temperatures, shatter resistant with low temperatures, Speed "K" Clamps factory installed

## Application:

New work residential construction 2 HR fire resistive walls and ceilings (35 lbs. fan support and 50 lbs. fixture support), UL approved for back-to-back installation

**Box Diameter:** 3.5

**Standards:**

**ANSI / UL 514C: File No E30594**



**WARNING** - PROP 65  
[Click here for more information!](#)

## Fire Classification:

### Fire Test of Building Construction Materials

ANSI / UL 263: File No. CEYY.R9379 (Category / File No.)

Note: Products must also be certified to: ANSI / UL 514C

### Fire Resistance Classification in Wall Assemblies 2-Hours or less

For use in fire resistance walls constructed of min. 5-1/2

in. deep wood or nonbearing steel studs and gypsum wallboard and gypsum board with Classification periods of 2 hrs or less. Clearance between boxes and cutouts in wall shall not exceed 1/8 in. The area of openings for boxes shall not aggregate more than 100 sq in. per 100 sq ft of wall or partition area with no opening exceeding 22.0 sq in. \*Outlet boxes with the suffix -NK, -NGK, -NKFR, -HNK, -HNGK, -SSK may be installed back to back on opposite sides of wall or partition.

*\*Applies to: 9335 (-NK), (-HNK), (-NGK), (-HNGK), (-NKFR); 9336 (-NK), (-NGK), (-HNK), (-HNGK); 9350 (-HNK); 9351 (-NK), (-NGK), (-NKFR), (-SSK); 9352 (-NK), (-NGK); and 9365 (-NK)*

**Fire Resistance Classification in Floor-Ceiling Assemblies 2-Hours or Less**

Distance between boxes in adjacent cavities may be reduced to 5 ½ inches, excluding open web trusses

*Note: For more details please refer to the UL fire resistive directory and Allied Moulded's CEYY.9379 (Outlet boxes and fittings classified for fire resistance.) See UL Product iQ document attached below.*

---