ALLIED MOULDED PRODUCTS, Inc.

419-636-4217
222 N. Union St.
Bryan, OH 43506



# 9305-GK

3.5" dia. round fixture support box for use with nonmetallic sheathed cable *Replacement for 9305-G*

**Carton Quantity:** 50

**Mounting Description:** Bottom mount button holes or flange holes

**Box Type:** Ceiling - Fixture

**Box Features:** Grounding strap, Speed "K" nonmetallic clamps

**Installation Type:** Old Work

**Width:** 3-1/2 (4-3/8 Flange O.D.) in

**Depth:** 1-3/4 in

**Volume:** 14 cu in

**Fixture Rating:** 50lbs

## Product Info

**Brand:** fiberglassBOX

**UPC:** 85339100362

**UNSPSC:** 39121316

**Carton Weight:** 17 lbs

**Carton Length:** 21 in

**Carton Width:** 10 in

**Carton Height:** 11 in

**Country of Origin:** United States of America

**Color:** Off white

**Material:** Fiberglass reinforced polyester

**Additional Materials:** Galvanized ground strap with plated carbon steel fastener and green plated carbon steel ground screw, Polyvinyl chloride clamps

**Box Diameter:** 3.5

**Features:**

Machine tapped fixture holes, ground strap, round exterior for easy cut-in, rigid hard box construction, no distortion with high temperatures, shatter resistant with low temperatures, Speed “K” Clamps factory installed

**Application:**

Old work residential construction 2 HR fire resistive walls (15 lbs fixture support – flange mount) and ceilings (50 lbs. fixture support – bottom mounted)

**Box Diameter:** 3.5

**Standards:**

ANSI / UL 514C: File No. E30594

LISTED

**WARNING** – PROP 65
Click here for more information!

**Fire Classification:**

**Fire Test of Building Construction Materials**

ANSI / UL 263: File No. CEYY.R9379 (Category / File No.)
Note: Products must also be certified to: ANSI / UL 514C

**Fire Resistance Classification in Wall Assemblies 2-Hours or less**

Shall be separated by a horizontal distance of not less

than 3 inches

**Fire Resistance Classification in Floor-Ceiling Assemblies 2-Hours or Less**

Distance between boxes in adjacent cavities may be reduced to 5 ½ inches

*Note: For more details please refer to the UL fire resistive directory and Allied Moulded's CEYY.9379 (Outlet boxes and fittings classified for fire resistance)*