



**ALLIED  
MOULDED  
PRODUCTS, Inc.**

**419-636-4217  
222 N. Union St.  
Bryan, OH 43506**



## Product Info

**Brand:** fiberglassBOX

**UPC:** 85339682912

**UNSPSC:** 39121316

**Carton Weight:** 19 lbs

**Carton Length:** 20 in

**Carton Width:** 17 in

**Carton Height:** 11 in

**Country of Origin:** United States of America

**Color:** Off white

**Material:** Fiberglass reinforced polyester

**Additional Materials:** Polyvinyl chloride clamps

**Box Diameter:** 3.5

## 9355-K

3.5" dia. round fixture support box for use with nonmetallic sheathed cable *Replacement for 9355*

**Carton Quantity:** 48

**Mounting Description:** Bottom mount button holes or flange holes

**Box Type:** Ceiling - Fixture

**Box Features:** Speed "K" nonmetallic clamps

**Installation Type:** Old Work

**Width:** 3-1/2 in

**Depth:** 2-3/4 in

**Volume:** 22 cu in

**Fixture Rating:** 50lbs

### Features:

Machine tapped fixture holes, round exterior for easy cut-in, rigid hard box construction, no distortion with high temperatures, shatter resistant with low temperatures, Speed "K" Clamps factory installed

### Application:

Old work residential construction 2 HR fire resistive walls (15 lbs fixture support - flange mount) and ceilings (50 lbs. fixture support - bottom mounted)

**Box Diameter:** 3.5

**Standards:**

ANSI / UL 514C: [File No. E30594](#)



**LISTED**

### Fire Classification:

#### Fire Test of Building Construction Materials

ANSI / UL 263: File No. CEYY.R9379 (Category / File No.)

Note: Products must also be certified to: ANSI / UL 514C

#### Fire Resistance Classification in Wall Assemblies 2-Hours or less

Shall be separated by a horizontal distance of not less than 3 inches

#### Fire Resistance Classification in Floor-Ceiling Assemblies 2-Hours or Less

Distance between boxes in adjacent cavities may be reduced to 5 ½ inches

*Note: For more details please refer to the UL fire resistive directory and Allied Moulded's CEYY.9379 (Outlet boxes and fittings classified for fire resistance)*

---