



## Product Info

**Brand:** fiberglassBOX

**UPC:** 85339881117

**UNSPSC:** 39121316

**Carton Weight:** 32 lbs

**Carton Length:** 16 in

**Carton Width:** 15 in

**Carton Height:** 11 in

**Country of Origin:** United States of America

**Color:** Off white

**Material:** Fiberglass reinforced polyester

**Additional Materials:** Galvanized ground strap with plated carbon steel fastener and green plated carbon steel ground screw, Galvanized steel brackets and plated carbon steel fasteners, Polyvinyl chloride clamps

**Box Diameter:** 4

## 9350-BHGK

4" dia. round fixture support box for use with nonmetallic sheathed cable *Replacement for 9350-16GK*

**Carton Quantity:** 24

**Mounting Description:** Adjustable bar hanger - 16" to 24" on center joist application

**Box Type:** Ceiling - Fixture

**Box Features:** Bar hanger, Grounding strap, Speed "K" nonmetallic clamps

**Installation Type:** New Work

**Width:** 4 in

**Depth:** 2-7/16 in

**Volume:** 22.5 cu in

**Fixture Rating:** 50lbs

### Features:

Machine tapped fixture holes, ground strap, rigid hard box construction, no distortion with high temperatures, shatter resistant with low temperatures, Speed "K" Clamps factory installed

### Application:

New work residential construction 2 HR fire resistive walls and ceilings (50 lbs. fixture support)

**Box Diameter:** 4

### Standards:

ANSI / UL 514C: [File No. E30594](#)



**LISTED**

### Fire Classification:

#### Fire Test of Building Construction Materials

ANSI / UL 263: [File No. CEYY.R9379](#) (Category / File No.)

Note: Products must also be certified to: ANSI / UL 514C

#### Fire Resistance Classification in Wall Assemblies 2-Hours or less

Shall be separated by a horizontal distance of not less than 3 inches

#### Fire Resistance Classification in Floor-Ceiling Assemblies 2-Hours or Less

Distance between boxes in adjacent cavities may be

reduced to 5 ½ inches

*Note: For more details please refer to the UL fire resistive directory and Allied Moulded's CEYY.9379 (Outlet boxes and fittings classified for fire resistance)*

---