



**ALLIED  
MOULDED  
PRODUCTS, Inc.**

**419-636-4217  
222 N. Union St.  
Bryan, OH 43506**



## 9350-BHKV2

4" dia. round fixture support box for use with nonmetallic sheathed cable

**Carton Quantity:** 18

**Mounting Description:** Adjustable bar hanger - 16" to 24" on center joist application

**Box Type:** Ceiling - Fixture

**Box Features:** Air-sealed flange (energy efficient), Bar hanger, Speed "K" nonmetallic clamps

**Installation Type:** New Work

**Width:** 4 in

**Depth:** 2-7/16 in

**Volume:** 22.5 cu in

**Fixture Rating:** 50lbs

## Product Info

**Brand:** Vapor Seal

**UPC:** 85339104841

**UNSPSC:** 39121316

**Carton Weight:** 26 lbs

**Carton Length:** 17 in

**Carton Width:** 15 in

**Carton Height:** 11 in

**Country of Origin:** United States of America

**Color:** Off white

**Patents:** U.S. Patent No. 6,908,003 B2

**Material:** Fiberglass reinforced polyester

**Additional Materials:** Galvanized steel brackets and plated carbon steel fasteners, Polyurethane flange, Polyvinyl chloride clamps

**Box Diameter:** 4

## Features:

Polyurethane flange for double drywall offset, machine tapped fixture holes, rigid hard box construction, no distortion with high temperatures, shatter resistant with low temperatures, Speed "K" Clamps factory installed

## Application:

New work residential construction 2 HR fire resistive walls and ceilings (50 lbs. fixture support) – air-sealed electrical box for envelope walls and ceilings in Energy Star homes

**Box Diameter:** 4

## Standards:

ANSI / UL 514C: [File No. E30594](#)



**LISTED**

NEMA OS 4 – Energy Efficient Air-Sealed Boxes for Electrical Applications



## Fire Classification:

### Fire Test of Building Construction Materials

ANSI / UL 263: [File No. CEYY.R9379](#) (Category / File No.)

Note: Products must also be certified to: ANSI / UL 514C

## Fire Resistance Classification in Wall Assemblies 2-

**Hours or less**

Shall be separated by a horizontal distance of not less than 3 inches

**Fire Resistance Classification in Floor-Ceiling Assemblies 2-Hours or Less**

Distance between boxes in adjacent cavities may be reduced to 5 ½ inches

*Note: For more details please refer to the UL fire resistive directory and Allied Moulded's CEYY.9379 (Outlet boxes and fittings classified for fire resistance)*

---