ALLIED MOULDED PRODUCTS, Inc.

419-636-4217
222 N. Union St.
Bryan, OH 43506

# 9350-HNK

4" dia. round fixture support box for use with nonmetallic sheathed cable *Replacement for 9350-HN*

**Carton Quantity:** 50

**Mounting Description:** Nail-on backside HN hanger bracket for adjusting to additional wall/ceiling substrate

**Box Type:** Ceiling - Fixture

**Box Features:** "HN" bracket, Speed "K" nonmetallic clamps

**Installation Type:** New Work

**Width:** 4 in

**Depth:** 2-7/16 in

**Volume:** 22.5 cu in

**Fixture Rating:** 50lbs

## Product Info

**Brand:** fiberglassBOX

**UPC:** 85339104629

**UNSPSC:** 39121316

**Carton Weight:** 31 lbs

**Carton Length:** 22 in

**Carton Width:** 12 in

**Carton Height:** 13 in

**Country of Origin:** United States of America

**Color:** Off white

**Material:** Fiberglass reinforced polyester

**Additional Materials:** Galvanized steel brackets and plated carbon steel fasteners, Polyvinyl chloride clamps

**Box Diameter:** 4

**Features:**

Machine tapped fixture holes, rigid hard box construction, no distortion with high temperatures, shatter resistant with low temperatures, Speed “K” Clamps factory installed

**Application:**

New work residential construction 2 HR fire resistive walls and ceilings (50 lbs. fixture support), UL approved for back-to-back installation

**Box Diameter:** 4

**Standards:**

**ANSI / UL 514C: File No E30594**

**WARNING** – PROP 65
Click here for more information!

**Fire Classification:**

**Fire Test of Building Construction Materials**

ANSI / UL 263: File No. CEYY.R9379 (Category / File No.)

Note: Products must also be certified to: ANSI / UL 514C

**Fire Resistance Classification in Wall Assemblies 2-Hours or less**

For use in fire resistance walls constructed of min. 5-1/2 in. deep wood or nonbearing steel studs and gypsum wallboard and gypsum board with Classification periods of 2 hrs or less. Clearance between boxes and cutouts in wall shall not exceed 1/8 in. The area of openings for boxes shall not aggregate more than 100 sq in. per 100 sq ft of wall or partition area with no opening exceeding 22.0 sq in. *Outlet boxes with the suffix -NK, -NGK, -NKFR, -HNK, -HNGK, -SSK may be installed back to back on opposite sides of wall or partition.

**Applies to: 9335 (-NK), (-HNK), (-NGK), (-HNGK), (-NKFR); 9336 (-NK), (-NGK), (-HNK), (-HNGK); 9350 (-HNK); 9351 (-NK), (-NGK), (-NKFR), (-SSK); 9352 (-NK), (-NGK); and 9365 (-NK)*

**Fire Resistance Classification in Floor-Ceiling Assemblies 2-Hours or Less**

Distance between boxes in adjacent cavities may be reduced to 5 ½ inches, excluding open web trusses

*Note: For more details please refer to the UL fire resistive directory and Allied Moulded's CEYY.9379 (Outlet boxes and fittings classified for fire resistance.) See UL Product iQ document attached below.*