



**ALLIED  
MOULDED  
PRODUCTS, Inc.**

**419-636-4217  
222 N. Union St.  
Bryan, OH 43506**



## Product Info

**Brand:** Vapor Seal

**UPC:** 85339927051

**UNSPSC:** 39121316

**Carton Weight:** 10 lbs

**Carton Length:** 17 in

**Carton Width:** 12 in

**Carton Height:** 8 in

**Country of Origin:** United States of America

**Color:** Off white

**Patents:** U.S. Patent No. 6,908,003 B2

**Material:** Fiberglass reinforced polyester

**Additional Materials:** Plated carbon steel fasteners,  
Polyurethane flange, Polyvinyl chloride clamps

**Box Diameter:** 4

## 9371-FRV

4" dia. round fixture support box for use with nonmetallic sheathed cable

**Carton Quantity:** 24

**Mounting Description:** Bottom mount

**Box Type:** Ceiling - Fan/Fixture

**Box Features:** Air-sealed flange (energy efficient)

**Installation Type:** New Work

**Width:** 4 in

**Depth:** 2-7/8 in

**Volume:** 12 cu in

**Fan Rating:** 70lbs

**Fixture Rating:** 110lbs

## Features:

Polyurethane flange for single drywall offset, 1/2" deep base with side cube wiring capacity, fan/fixture screws for joist mounting, machine tapped fixture holes, rigid hard box construction, no distortion with high temperatures, shatter resistant with low temperatures, Speed "K" Clamps factory installed

## Application:

New work residential construction 2 HR fire resistive walls and ceilings (70 lbs. fan support and 110 lbs. fixture support), air-sealed electrical fan support box for Energy Star homes

**Box Diameter:** 4

**Standards:**

ANSI / UL 514C: [File No. E30594](#)



**LISTED**

NEMA OS 4 - Energy Efficient Air-Sealed Boxes for Electrical Applications



**WARNING** - PROP 65  
[Click here for more information!](#)

**Fire Classification:**

**Fire Test of Building Construction Materials**

ANSI / UL 263: File No. CEYY.R9379 (Category / File No.)  
Note: Products must also be certified to: ANSI / UL 514C

**Fire Resistance Classification in Wall Assemblies 2-Hours or less**

Shall be separated by a horizontal distance of not less than 3 inches

**Fire Resistance Classification in Floor-Ceiling Assemblies 2-Hours or Less**

Distance between boxes in adjacent cavities may be reduced to 5 ½ inches

*Note: For more details please refer to the UL fire resistive directory and Allied Moulded's CEYY.9379 (Outlet boxes and fittings classified for fire resistance)*

---