



**ALLIED  
MOULDED  
PRODUCTS, Inc.**

**419-636-4217  
222 N. Union St.  
Bryan, OH 43506**



## PC244OWG

4" dia. round fixture support box for use with nonmetallic sheathed cable

**Carton Quantity:** 24

**Mounting Description:** Metal wing brackets/nonmetal ears wall compression

**Box Type:** Wall - Fixture Support

**Box Features:** Grounding strap, Nonmetal ears, Wing bracket

**Installation Type:** Old Work

**Width:** 4 in

**Depth:** 3 in

**Volume:** 24.5 cu in

## Product Info

**Brand:** flexBOX

**UPC:** 85339974185

**UNSPSC:** 39121316

**Carton Weight:** 7 lbs

**Carton Length:** 20 in

**Carton Width:** 14 in

**Carton Height:** 7 in

**Country of Origin:** United States of America

**Color:** Black

**Patents:** U.S. Patent No. 6,365,831 B1

**Material:** Polycarbonate

**Additional Materials:** Galvanized ground strap with plated carbon steel fastener and green plated carbon steel ground screw, Galvanized steel brackets and plated carbon steel fasteners

**Box Diameter:** 4

### Features:

Machine tapped fixture holes, round exterior for easy cut-in, ground strap

### Application:

Old work residential construction 2 HR fire resistive walls. Meets requirements of Articles 314.27 (A1) and 314.27 (D) of the 2014 NEC. Suitable for use in mounting utilization equipment (wall sconce lights, alarm system strobe/speaker, smoke detector and low-profile LED lighting) weighing six pounds or less.

**Box Diameter:** 4

### Standards:

ANSI / UL 514C: [File No. E30594](#)



**LISTED**

 **WARNING** - PROP 65  
[Click here for more information!](#)

### Fire Classification:

#### Fire Test of Building Construction Materials

ANSI / UL 263: File No. CEYY.R9379 (Category / File No.)

*Note: Products must also be certified to: ANSI / UL 514C*

#### Fire Resistance Classification in Floor-Ceiling

**Assemblies 2-Hours or Less**

Distance between boxes in adjacent cavities may be reduced to 5 ½ inches

*Note: For more details please refer to the UL fire resistive directory and Allied Moulded's CEYY.9379 (Outlet boxes and fittings classified for fire resistance)*

---