



ALLIED  
MOULDED  
PRODUCTS, Inc.

419-636-4217  
222 N. Union St.  
Bryan, OH 43506



## 1099-NV

Single gang electrical box for use with nonmetallic sheathed cable

**Carton Quantity:** 48

**Mounting Description:** Angled mid nails

**Box Type:** Wall - Switch/Receptacle

**Box Features:** Air-sealed flange (energy efficient), Nails

**Installation Type:** New Work

**Height:** 3-27/32 in

**Width:** 2-1/4 in

**Depth:** 3-9/16 in

**Volume:** 22.5 cu in

**Number of Gangs:** 1

## Product Info

**Brand:** Vapor Seal

**UPC:** 85339260073

**UNSPSC:** 39121308

**Carton Weight:** 21 lbs

**Carton Length:** 20 in

**Carton Width:** 16 in

**Carton Height:** 10 in

**Country of Origin:** United States of America

**Color:** Off white

**Patents:** U.S. Patent No. 6,908,003 B2

**Material:** Fiberglass reinforced polyester

**Additional Materials:** Carbon steel fasteners, Polyurethane flange

## Features:

Polyurethane flange for single drywall offset, machine tapped device holes, leveling ribs, rigid hard box construction, no distortion with high temperatures, shatter resistant with low temperatures

## Application:

New work residential construction 2 HR fire resistive walls & ceilings – air-sealed electrical boxes for envelope walls and ceilings in Energy Star homes

## Standards:

ANSI / UL 514C: [File No. E30594](#)



**LISTED**

NEMA OS 4 – Energy Efficient Air-Sealed Boxes for Electrical Applications



## Fire Classification:

**Fire Test of Building Construction Materials**

ANSI / UL 263: [File No. CEYY.R9379](#) (Category / File No.)

Note: Products must also be certified to: ANSI / UL 514C

**Fire Resistance Classification in Wall Assemblies 2-Hours or less**

Shall be separated by a horizontal distance of not less than 3 inches

**Fire Resistance Classification in Floor-Ceiling Assemblies 2-Hours or Less**

Distance between boxes in adjacent cavities may be reduced to 5 ½ inches

*Note: For more details please refer to the UL fire resistive directory and Allied Moulded's CEYY.9379 (Outlet boxes and fittings classified for fire resistance)*

---