



## 3300-NBK

Three gang electrical box for use with nonmetallic sheathed cable *Replacement for 3300-NB*

**Carton Quantity:** 20

**Mounting Description:** Angled mid nails with adjustable stabilizer bar

**Box Type:** Wall - Switch/Receptacle

**Box Features:** Adjustable stabilizing bar, Nails, Wire clamps

**Installation Type:** New Work

**Height:** 3-3/4 in

**Width:** 5-11/16 in

**Depth:** 3 in

**Volume:** 46 cu in

**Number of Gangs:** 3

## Product Info

**Brand:** fiberglassBOX

**UPC:** 85339142126

**UNSPSC:** 39121308

**Carton Weight:** 21 lbs

**Carton Length:** 18 in

**Carton Width:** 15 in

**Carton Height:** 16 in

**Country of Origin:** United States of America

**Color:** Off white

**Material:** Fiberglass reinforced polyester

**Additional Materials:** Carbon steel fasteners, Galvanized steel brackets and plated carbon steel fasteners, Polyvinyl chloride clamps

## Features:

Machine tapped device holes, offset gauge marks, leveling ribs, rigid hard box construction, no distortion with high temperatures, shatter resistant with low temperatures, Speed "K" Clamps factory installed

## Application:

New work residential construction 2 HR fire resistive walls, UL approved for back-to-back installation

## Standards:

**ANSI / UL 514C: File No E30594**



**WARNING - PROP 65**  
[Click here for more information!](#)

## Fire Classification:

### Fire Test of Building Construction Materials

ANSI / UL 263: File No. CEYY.R9379 (Category / File No.)

Note: Products must also be certified to: ANSI / UL 514C

### Fire Resistance Classification in Wall Assemblies 2-Hours or less

For use in fire resistance walls constructed of min. 5-1/2

in. deep wood or nonbearing steel studs and gypsum wallboard and gypsum board with Classification periods of 2 hrs or less. Clearance between boxes and cutouts in wall shall not exceed 1/8 in. The area of openings for boxes shall not aggregate more than 100 sq in. per 100 sq ft of wall or partition area with no opening exceeding 22.0 sq in. \*Outlet boxes with the suffix -N, -NK, NBK, -NC2, -NMHK, -SS, -SSK, -42, and -42SS may be installed back to back on opposite sides of wall or partition.

*\* Applies to: 2300 (-NK); 2302 (-NK), (-SSK); 9372 (-NMHK); RD (-42), (-42SS); 3300 (-NK), (-NBK); 3303 (-NK), (-NBK), (-SSK); and 9343 (-NK), (-SSK), (-NC2)*

*Note: For more details please refer to the UL fire resistive directory and Allied Moulded's CEYY.9379 (Outlet boxes and fittings classified for fire resistance.) See UL Product iQ document attached below.*

---