




**ALLIED  
MOULDED  
PRODUCTS, Inc.**

**419-636-4217  
222 N. Union St.  
Bryan, OH 43506**



## 3300-Z2BK

Three gang electrical box for use with nonmetallic sheathed cable *Replacement for 3300-Z2B*

**Carton Quantity:** 20

**Mounting Description:** Stud mount "Z" hanger bracket with 1/4" offset with adjustable stabilizer bar

**Box Type:** Wall - Switch/Receptacle

**Box Features:** "Z" hanger(s), Adjustable stabilizing bar, Speed "K" nonmetallic clamps

**Installation Type:** New Work

**Height:** 3-3/4 in

**Width:** 5-11/16 in

**Depth:** 3 in

**Volume:** 46 cu in

**Number of Gangs:** 3

## Product Info

**Brand:** fiberglassBOX

**UPC:** 85339145974

**UNSPSC:** 39121308

**Carton Weight:** 25 lbs

**Carton Length:** 17 in

**Carton Width:** 16 in

**Carton Height:** 16 in

**Country of Origin:** United States of America

**Color:** Off white

**Material:** Fiberglass reinforced polyester

**Additional Materials:** Galvanized steel brackets and plated carbon steel fasteners, Polyvinyl chloride clamps

### Features:

Machine tapped device holes, leveling ribs, rigid hard box construction, no distortion with high temperatures, shatter resistant with low temperatures, Speed "K" Clamps factory installed

### Application:

New work residential construction stud face mounted 2 HR fire resistive walls

### Standards:

ANSI / UL 514C: [File No. E30594](#)



**LISTED**



**WARNING** - PROP 65

[Click here for more information!](#)

### Fire Classification:

#### Fire Test of Building Construction Materials

ANSI / UL 263: File No. CEYY.R9379 (Category / File No.)

*Note: Products must also be certified to: ANSI / UL 514C*

#### Fire Resistance Classification in Wall Assemblies 2-Hours or less

Shall be separated by a horizontal distance of not less

than 3 inches

*Note: For more details please refer to the UL fire resistive directory and Allied Moulded's CEYY.9379 (Outlet boxes and fittings classified for fire resistance)*

---