




**ALLIED  
MOULDED  
PRODUCTS, Inc.**

**419-636-4217  
222 N. Union St.  
Bryan, OH 43506**



## 9312-EWK

Two gang electrical box for use with nonmetallic sheathed cable *Replacement for 9312-EW and 9312-EWC4*

**Carton Quantity:** 50

**Mounting Description:** Metal wing brackets/metal ears wall compression

**Box Type:** Wall - Switch/Receptacle

**Box Features:** Metal ears, Speed "K" nonmetallic clamps, Wing bracket

**Installation Type:** Old Work

**Height:** 3-1/4 in

**Width:** 4-1/8 in

**Depth:** 2-3/4 in

**Volume:** 28 cu in

**Number of Gangs:** 2

## Product Info

**Brand:** fiberglassBOX

**UPC:** 85339291114

**UNSPSC:** 39121308

**Carton Weight:** 25 lbs

**Carton Length:** 19 in

**Carton Width:** 9 in

**Carton Height:** 15 in

**Country of Origin:** United States of America

**Color:** Off white

**Material:** Fiberglass reinforced polyester

**Additional Materials:** Galvanized steel brackets and plated carbon steel fasteners, Polyvinyl chloride clamps

### Features:

Machine tapped device holes, rigid hard box construction, no distortion with high temperatures, shatter resistant with low temperatures, Speed "K" Clamps factory installed

### Application:

Old work residential construction 2 HR fire resistive walls

### Standards:

ANSI / UL 514C: [File No. E30594](#)



**LISTED**



**WARNING** - PROP 65

[Click here for more information!](#)

### Fire Classification:

#### Fire Test of Building Construction Materials

ANSI / UL 263: File No. CEYY.R9379 (Category / File No.)

*Note: Products must also be certified to: ANSI / UL 514C*

#### Fire Resistance Classification in Wall Assemblies 2-Hours or less

Shall be separated by a horizontal distance of not less than 3 inches

*Note: For more details please refer to the UL fire resistive directory and Allied Moulded's CEYY.9379 (Outlet boxes and fittings classified for fire resistance)*

---