



**ALLIED  
MOULDED  
PRODUCTS, Inc.**

**419-636-4217  
222 N. Union St.  
Bryan, OH 43506**



## 5305-Z4BK

Five gang electrical box for use with nonmetallic sheathed cable

**Carton Quantity:** 6

**Closure Type:**

**Mounting Description:** Stud mount "Z" hanger bracket with 1/2" offset and adjustable stabilizer bar

**Box Type:** Wall - Switch/Receptacle

**Box Features:** Adjustable stabilizing bar, "Z" hanger(s), Speed "K" nonmetallic clamps

**Installation Type:** New Work

**Height:** 3-3/4 in

**Width:** 9-5/16 in

**Depth:** 3-9/16 in

**Volume:** 94 cu in

**Number of Gangs:** 5

## Product Info

**Brand:** fiberglassBOX

**UPC:** 85339180036

**UNSPSC:** 39121308

**Carton Weight:** 12 lbs

**Carton Length:** 16 in

**Carton Width:** 15 in

**Carton Height:** 9 in

**Country of Origin:** United States of America

**Color:** Off white

**Material:** Fiberglass reinforced polyester

**Additional Materials:** Galvanized steel brackets and plated carbon steel fasteners, Polyvinyl chloride clamps

## Features:

Machine tapped device holes, slot provision for low voltage divider, leveling ribs, rigid hard box construction, no distortion with high temperatures, shatter resistant with low temperatures, Speed "K" Clamps factory installed

## Application:

New work residential construction stud face mounted 2 HR fire resistive walls

## Standards:

ANSI / UL 514C: [File No. E30594](#)



**LISTED**

**WARNING** - PROP 65  
[Click here for more information!](#)

## Fire Classification:

### Fire Test of Building Construction Materials

ANSI / UL 263: File No. CEYY.R9379 (Category / File No.)

*Note: Products must also be certified to: ANSI / UL 514C*

**Fire Resistance Classification in Wall Assemblies 2-Hours or less**

Shall be separated by a horizontal distance of not less than 24 inches

*Note: For more details please refer to the UL fire resistive directory and Allied Moulded's CEYY.9379 (Outlet boxes and fittings classified for fire resistance)*

---