

The Newest Additions to the flexBOX® Vapor Seal® Line!

Vapor Seal® products provide a solution to prevent air infiltration/air leakage on exterior walls and aid in gaining an Energy Star Rating.

NEW



Sealed clamps means no caulk or additional sealing!



P-442NV

Two gang Vapor Seal® electrical box for use with nonmetallic sheathed cable.



MEASUREMENTS

- Height: 3-9/16 in
- Width: 4 in
- Depth: 3-3/4 in
- Volume: 43 cu in
- Number of Gangs: 2

CONSTRUCTION

- Polycarbonate new work
- Carbon steel fasteners
- Thermoplastic Polyester Elastomer (TPE)
- Sealed TPE Clamps

FEATURES

- TPE flange for single 1/2" & 5/8" drywall
- Molded-in splined device holes
- Leveling ribs

STANDARDS

- ANSI / UL 514C: File No. E30594
- UL Listed
- NEMA OS 4 (Energy Efficient)

FIRE CLASSIFICATION

Fire Test of Building Construction Materials

ANSI / UL 263: File No. CEYY.R9379 (Category / File No.)

Note: Products must also be certified to: ANSI / UL 514C

Fire Resistance Classification in Wall Assemblies 2-Hours or less

Shall be separated by a horizontal distance of not less than 24 inches

Note: For more details please refer to the UL fire resistive directory and Allied Moulded's CEYY.9379 (Outlet boxes and fittings classified for fire resistance)

The Newest Additions to the flexBOX® Vapor Seal® Line!

PC234-NV PC234-NGV*

4" dia. round Vapor Seal® fixture support box for use with nonmetallic sheathed cable.

*PC234-NGV has a grounding strap

MEASUREMENTS

- Width: 5-1/4 in
- Depth: 2-5/16 in
- Volume: 23 cu in
- Fixture Rating: 50 lbs

CONSTRUCTION

- Polycarbonate new work
- Carbon steel fasteners
- Thermoplastic Polyester Elastomer (TPE)
- Sealed TPE Clamps

FIRE CLASSIFICATION

Fire Test of Building Construction Materials

ANSI / UL 263: File No. CEYY.R9379 (Category / File No.)

Note: Products must also be certified to: ANSI / UL 514C

Fire Resistance Classification in Floor-Ceiling Assemblies 2-Hours or less

Distance between boxes in adjacent cavities may be reduced to 5 1/2 inches

Note: For more details please refer to the UL fire resistive directory and Allied Moulded's CEYY.9379 (Outlet boxes and fittings classified for fire resistance)

FEATURES

- TPE flange for single 1/2" & 5/8" drywall offset
- Molded-in splined device holes
- Fixture support

STANDARDS

- ANSI / UL 514C: File No. E30594
- UL Listed
- NEMA OS 4 (Energy Efficient)

PC234-BHV PC234-BHGV*

4" dia. round Vapor Seal® fixture support box for use with nonmetallic sheathed cable.

*PC234-BHGV has a grounding strap

MEASUREMENTS

- Width: 5-1/4 in
- Depth: 2-5/16 in
- Volume: 23 cu in
- Fixture Rating: 50 lbs

CONSTRUCTION

- Polycarbonate new work
- Carbon steel fasteners
- Thermoplastic Polyester Elastomer (TPE)
- Sealed TPE Clamps

FIRE CLASSIFICATION

Fire Test of Building Construction Materials

ANSI / UL 263: File No. CEYY.R9379 (Category / File No.)

Note: Products must also be certified to: ANSI / UL 514C

Fire Resistance Classification in Floor-Ceiling Assemblies 2-Hours or less

Distance between boxes in adjacent cavities may be reduced to 5 1/2 inches

Note: For more details please refer to the UL fire resistive directory and Allied Moulded's CEYY.9379 (Outlet boxes and fittings classified for fire resistance)

FEATURES

- TPE flange for single 1/2" & 5/8" drywall offset
- Molded-in splined device holes
- Fixture support with adjustable bar hanger

STANDARDS

- ANSI / UL 514C: File No. E30594
- UL Listed
- NEMA OS 4 (Energy Efficient)